

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 1 **Description:** 13A 2m 4 Gang Ext **Testcode:**
Lead

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.12	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

PMS

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 2 **Description:** 13A 1M Ext Lead 4 way **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.04	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

N/A

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 3 **Description:** 13A 1M Ext Lead 4 way **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.04	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

PMS

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 4 **Description:** 13A 1M Ext Lead 4 way **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	10	A	Information
Fuse Rating	10	Amp	Information
IEC Lead Continuity	0.04	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Master Plug

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 6 **Description:** 2M 3 Way Ext Lead **Testcode:**
Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.08	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

N/A

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 7 **Description:** 4 Way Ext Lead 5M Reel **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	10	A	Information
Fuse Rating	10	Amp	Information
IEC Lead Continuity	0.11	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Homebase

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 8 **Description:** 13A 4 way S/P 2M Ext Lead **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.1	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	3.75	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Surgemaster

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 9 **Description:** 4 Way 2M S/P Ext Lead **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.08	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Belkin

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 10 **Description:** 4 Way Ext Lead 10M Reel **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.27	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Masterplug

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 11 **Description:** 25M 4 Way Ext Reel **Testcode:**
Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.39	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Pifco

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 12 **Description:** 20 metre 4G Ext Reel **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.32	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Focus

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 13

Description: 2M 6G Ext Lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.05	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Master Plug

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 14

Description: 2m IEC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Voltage	230	V	Information
Power Rating	5	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.08	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 15

Description: 2m IEC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	3	Amp	Information
IEC Lead Continuity	0.05	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 16

Description: 2m IEC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	10	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	10	Amp	Information
IEC Lead Continuity	0.1	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 17

Description: 2m IEC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.06	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 25/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 18

Description: 2m IEC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.09	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 19

Description: 2m ieC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.06	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 20

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.09	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 21

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.11	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 22

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.04	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 23

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.08	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 24

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.07	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 25

Description: 2m IeC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.06	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 26

Description: 2m ieC lead

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	5	Amp	Information
IEC Lead Continuity	0.05	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 27

Description: USB Charger

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	2.5	A	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	242.4	V	Information
Load Current	0.05	A	Information
Touch Current	0.01	mA	Pass

Comments:

Apple

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 28

Description: USB Charger

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	2.5	A	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	238.6	V	Information
Load Current	0.05	A	Information
Touch Current	0.02	mA	Pass

Comments:

Generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 29

Description: Rope Light

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	3	Amp	Information

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 30

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	243.1	V	Information
Load Current	0.069	A	Information
Touch Current	0.01	mA	Pass

Comments:

Solmore

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 31

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	247.9	V	Information
Load Current	0.058	A	Information
Touch Current	0.01	mA	Pass

Comments:

Solmore

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 32

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	244	V	Information
Load Current	0.052	A	Information
Touch Current	0.01	mA	Pass

Comments:

Generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 33

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	237.5	V	Information
Load Current	0.052	A	Information
Touch Current	0.01	mA	Pass

Comments:

Generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 34

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	249.7	V	Information
Load Current	0.05	A	Information
Touch Current	0.01	mA	Pass

Comments:

generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 35

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	1	W	Information
Fuse Rating	5	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	249.7	V	Information
Load Current	0.052	A	Information
Touch Current	0.01	mA	Pass

Comments:

generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 36

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	8	W	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.03	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	247	V	Information
Load Current	0.055	A	Information
PE Conductor Current	0.03	mA	Pass

Comments:

Beamz

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 37

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	8	W	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.04	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	245.3	V	Information
Load Current	0.055	A	Information
PE Conductor Current	0.03	mA	Pass

Comments:

Beamz

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 38

Description: Halogen Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.04	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	248.8	V	Information
Load Current	2.296	A	Information
PE Conductor Current	0.04	mA	Pass

Comments:

generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 39

Description: Halogen Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.04	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	245.5	V	Information
Load Current	0.094	A	Information
PE Conductor Current	0.03	mA	Pass

Comments:

generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 40 **Description:** Switching Power Adaptor **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	240.4	V	Information
Load Current	0.05	A	Information
Touch Current	0.01	mA	Pass

Comments:

Sennheiser

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 41

Description: Lighting Controller

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	247.4	V	Information
Load Current	0.05	A	Information
Touch Current	0.01	mA	Pass

Comments:

Colormix CA-32

PL-11060863

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 42

Description: 10 inch Speaker

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	1.25	A	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.09	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	245.8	V	Information
Load Current	0.066	A	Information
PE Conductor Current	0.12	mA	Pass

Comments:

Mackie

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 43

Description: 10 inch Speaker

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	1.25	A	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.07	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	241.3	V	Information
Load Current	0.066	A	Information
PE Conductor Current	0.09	mA	Pass

Comments:

Mackie

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 44

Description: 15 inch Speaker

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	1000	W	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.08	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	247.9	V	Information
Load Current	0.108	A	Information
PE Conductor Current	0.43	mA	Pass

Comments:

Mackie

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 45

Description: 15 inch Speaker

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	1000	W	Information
Fuse Rating	13	Amp	Information
Earth Continuity	0.07	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	245.7	V	Information
Load Current	0.097	A	Information
PE Conductor Current	0.42	mA	Pass

Comments:

Mackie

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 46

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	1	A	Information
Earth Continuity	0.07	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	249.1	V	Information
Load Current	0.052	A	Information
PE Conductor Current	0.03	mA	Pass

Comments:

Kam Partybar

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 47

Description: LED Lamp

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	1	A	Information
Earth Continuity	0.1	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	248.9	V	Information
Load Current	0.055	A	Information
PE Conductor Current	0.03	mA	Pass

Comments:

Kam Partybar

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 48

Description: Mixing Desk

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	30	W	Information
Earth Continuity	0.07	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	243.4	V	Information
Load Current	0.091	A	Information
PE Conductor Current	0.17	mA	Pass

Comments:

Mackie Pro FX 12

03290700BPED0602

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 49

Description: Figure 8 1M LEAD

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	244	V	Information
Load Current	0.097	A	Information
Touch Current	0.01	mA	Pass

Comments:

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 50 **Description:** Switching Power Adaptor **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	238.3	V	Information
Load Current	0.05	A	Information
Touch Current	0.11	mA	Pass

Comments:

Generic

Overall Status: Pass

Date Of Test: 25/02/2020

Next Test Due: 03/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 51 **Description:** 20 metre 4G Ext Reel **Testcode:**

Make: **Model:** **Serial No:**

Test	Result	Unit	Status
Plug			Pass
Flex			Pass
Enclosure			Pass
Socket			Pass
Voltage	230	V	Information
Power Rating	13	A	Information
Fuse Rating	13	Amp	Information
IEC Lead Continuity	0.46	ohm	Pass
Insulation Voltage	500	V	Information
Insulation	> 19.99	MOhm	Pass
IEC Lead Polarity			Pass

Comments:

Jo Jo

Overall Status: Pass

Date Of Test: 05/03/2020

Next Test Due: 12/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By:

Test Certificate

Test Conducted By: Artattaxe Ltd, Unit 1, Dragons Industrial Units, Lloc, Flintshire, CH8 8RF

On Behalf Of: ,

Site: Tony Rapson

Location: Home

Asset & Test details

Asset: 52

Description: Tyros 5

Testcode:

Make:

Model:

Serial No:

Test	Result	Unit	Status
Enclosure			Pass
Environment			Pass
Socket			Pass
Switch			Pass
Voltage	230	V	Information
Power Rating	35	W	Information
Fuse Rating	5	Amp	Information
Earth Continuity	0.12	ohm	Pass
Insulation Voltage	250	V	Information
Insulation	> 19.99	MOhm	Pass
Live Voltage	244.5	V	Information
Load Current	0.091	A	Information
PE Conductor Current	0.33	mA	Pass

Comments:

Yamaha

Overall Status: Pass

Date Of Test: 05/03/2020

Next Test Due: 12/03/2020

Test Instrument: Seaward Apollo 600 40H-0593

Tested By: K McCarth

Signed By: