

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

<b>Client:</b>	<b>Site: Tony Rapson</b>	<b>Location: Home</b>
Asset ID: 1	Description: 13A 2m 4 Gang Ext Lead	User: K McCarth Test Instrument: 40H-0593
Comments: PMS		

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.12	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 2	Description: 13A 1M Ext Lead 4 way	User: K McCarth Test Instrument: 40H-0593
Comments: N/A		

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 3	Description: 13A 1M Ext Lead 4 way	User: K McCarth Test Instrument: 40H-0593
Comments: PMS		

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 4	Description: 13A 1M Ext Lead 4 way	User: K McCarth Test Instrument: 40H-0593
Comments: Master Plug		

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	10	A	Information
Fuse Rating	25/02/2020	10	Amp	Information
IEC Lead Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Overall: Pass

Asset ID: 5	Description: 13A 2m 4way Ext Lead	User: K McCarth	Test Instrument: 40H-0593
Comments: Micromark			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 6	Description: 2M 3 Way Ext Lead	User: K McCarth	Test Instrument: 40H-0593
Comments: N/A			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 7	Description: 4 Way Ext Lead 5M Reel	User: K McCarth	Test Instrument: 40H-0593
Comments: Homebase			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	10	A	Information
Fuse Rating	25/02/2020	10	Amp	Information
IEC Lead Continuity	25/02/2020	0.11	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 8	Description: 13A 4 way S/P 2M Ext Lead	User: K McCarth	Test Instrument: 40H-0593
Comments: Surgemaster			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.1	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	3.75	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Overall: Pass

Asset ID: 9	Description: 4 Way 2M S/P Ext Lead	User: K McCarth	Test Instrument: 40H-0593
Comments: Belkin			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 10	Description: 4 Way Ext Lead 10M Reel	User: K McCarth	Test Instrument: 40H-0593
Comments: Masterplug			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.27	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 11	Description: 25M 4 Way Ext Reel	User: K McCarth	Test Instrument: 40H-0593
Comments: Pifco			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.39	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 12	Description: 20 metre 4G Ext Reel	User: K McCarth	Test Instrument: 40H-0593
Comments: Focus			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.32	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Overall: Pass

Asset ID: 13	Description: 2M 6G Ext Lead	User: K McCarth	Test Instrument: 40H-0593
Comments: Master Plug			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.05	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 14	Description: 2m IEC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	5	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 15	Description: 2m IEC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	3	Amp	Information
IEC Lead Continuity	25/02/2020	0.05	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 16	Description: 2m IEC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Fuse Rating	25/02/2020	10	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	10	Amp	Information
IEC Lead Continuity	25/02/2020	0.1	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 17	Description: 2m iEC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.06	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 18	Description: 2m iEC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.09	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 19	Description: 2m iEC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.06	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 20	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.09	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 21	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.11	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 22	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
IEC Lead Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 23	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 24	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.07	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 25	Description: 2m IeC lead	User: K McCarth	Test Instrument: 40H-0593
Comments:			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.06	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 26	Description: 2m ieC lead	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	5	Amp	Information
IEC Lead Continuity	25/02/2020	0.05	ohm	Pass
Insulation Voltage	25/02/2020	500	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
IEC Lead Polarity	25/02/2020			Pass

Overall: Pass

Asset ID: 27	Description: USB Charger	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments: Apple

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	2.5	A	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	242.4	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.01	mA	Pass

Overall: Pass

Asset ID: 28	Description: USB Charger	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments: Generic

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	2.5	A	Information



# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	238.6	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.02	mA	Pass

Overall: Pass

Asset ID: 29	Description: Rope Light	User: K McCarth	Test Instrument: 40H-0593
--------------	-------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	3	Amp	Information

Overall: Pass

Asset ID: 30	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------	-----------------	---------------------------

Comments: Solmore

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	243.1	V	Information
Load Current	25/02/2020	0.069	A	Information
Touch Current	25/02/2020	0.01	mA	Pass

Overall: Pass

Asset ID: 31	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------	-----------------	---------------------------

Comments: Solmore

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	247.9	V	Information
Load Current	25/02/2020	0.058	A	Information
Touch Current	25/02/2020	0.01	mA	Pass

Overall: Pass

Asset ID: 32	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------	-----------------	---------------------------

Comments: Generic

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	244	V	Information
Load Current	25/02/2020	0.052	A	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Touch Current	25/02/2020	0.01	mA	Pass
				Overall: Pass

Asset ID: 33	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: Generic			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	237.5	V	Information
Load Current	25/02/2020	0.052	A	Information
Touch Current	25/02/2020	0.01	mA	Pass
				Overall: Pass

Asset ID: 34	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: generic			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	249.7	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.01	mA	Pass
				Overall: Pass

Asset ID: 35	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: generic			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	W	Information
Fuse Rating	25/02/2020	5	Amp	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	249.7	V	Information
Load Current	25/02/2020	0.052	A	Information
Touch Current	25/02/2020	0.01	mA	Pass
				Overall: Pass

Asset ID: 36	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: Beamz			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	8	W	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.03	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	247	V	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Load Current	25/02/2020	0.055	A	Information
PE Conductor Current	25/02/2020	0.03	mA	Pass
Overall: Pass				

Asset ID: 37	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: Beamz			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	8	W	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	245.3	V	Information
Load Current	25/02/2020	0.055	A	Information
PE Conductor Current	25/02/2020	0.03	mA	Pass
Overall: Pass				

Asset ID: 38	Description: Halogen Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: generic			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	248.8	V	Information
Load Current	25/02/2020	2.296	A	Information
PE Conductor Current	25/02/2020	0.04	mA	Pass
Overall: Pass				

Asset ID: 39	Description: Halogen Lamp	User: K McCarth	Test Instrument: 40H-0593
Comments: generic			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.04	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	245.5	V	Information
Load Current	25/02/2020	0.094	A	Information
PE Conductor Current	25/02/2020	0.03	mA	Pass
Overall: Pass				

Asset ID: 40	Description: Switching Power Adaptor	User: K McCarth	Test Instrument: 40H-0593
Comments: Sennheiser			

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Insulation Voltage	25/02/2020	250	V	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	240.4	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.01	mA	Pass

Overall: Pass

Asset ID: 41	Description: Lighting Controller	User: K McCarth	Test Instrument: 40H-0593
Comments: Colormix CA-32 PL-11060863			

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	13	A	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	247.4	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.01	mA	Pass

Overall: Pass

Asset ID: 42	Description: 10 inch Speaker	User: K McCarth	Test Instrument: 40H-0593
Comments: Mackie			

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1.25	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.09	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	245.8	V	Information
Load Current	25/02/2020	0.066	A	Information
PE Conductor Current	25/02/2020	0.12	mA	Pass

Overall: Pass

Asset ID: 43	Description: 10 inch Speaker	User: K McCarth	Test Instrument: 40H-0593
Comments: Mackie			

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1.25	A	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.07	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	241.3	V	Information
Load Current	25/02/2020	0.066	A	Information
PE Conductor Current	25/02/2020	0.09	mA	Pass

Overall: Pass

Asset ID: 44	Description: 15 inch Speaker	User: K McCarth	Test Instrument: 40H-0593
Comments: Mackie			

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1000	W	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.08	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	247.9	V	Information
Load Current	25/02/2020	0.108	A	Information
PE Conductor Current	25/02/2020	0.43	mA	Pass

Overall: Pass

Asset ID: 45	Description: 15 inch Speaker	User: K McCarth	Test Instrument: 40H-0593
--------------	------------------------------	-----------------	---------------------------

Comments: Mackie

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1000	W	Information
Fuse Rating	25/02/2020	13	Amp	Information
Earth Continuity	25/02/2020	0.07	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	245.7	V	Information
Load Current	25/02/2020	0.097	A	Information
PE Conductor Current	25/02/2020	0.42	mA	Pass

Overall: Pass

Asset ID: 46	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------	-----------------	---------------------------

Comments: Kam Partybar

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	A	Information
Earth Continuity	25/02/2020	0.07	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	249.1	V	Information
Load Current	25/02/2020	0.052	A	Information
PE Conductor Current	25/02/2020	0.03	mA	Pass

Overall: Pass

Asset ID: 47	Description: LED Lamp	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------	-----------------	---------------------------

Comments: Kam Partybar

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	1	A	Information
Earth Continuity	25/02/2020	0.1	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	248.9	V	Information
Load Current	25/02/2020	0.055	A	Information
PE Conductor Current	25/02/2020	0.03	mA	Pass

Overall: Pass

Asset ID: 48	Description: Mixing Desk	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------	-----------------	---------------------------

Comments: Mackie Pro FX 12 03290700BPED0602

Test Type	Date	Result	Unit	Status
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power Rating	25/02/2020	30	W	Information
Earth Continuity	25/02/2020	0.07	ohm	Pass
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Live Voltage	25/02/2020	243.4	V	Information
Load Current	25/02/2020	0.091	A	Information
PE Conductor Current	25/02/2020	0.17	mA	Pass

Overall: Pass

Asset ID: 49	Description: Figure 8 1M LEAD	User: K McCarth	Test Instrument: 40H-0593
--------------	-------------------------------	-----------------	---------------------------

Comments:

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Power	25/02/2020	13	A	Information
Rating	25/02/2020	13	Amp	Information
Fuse Rating	25/02/2020	250	V	Information
Insulation Voltage	25/02/2020	> 19.99	MOhm	Pass
Insulation	25/02/2020	244	V	Information
Live Voltage	25/02/2020	0.097	A	Information
Load Current	25/02/2020	0.01	mA	Pass
Touch Current	25/02/2020			Pass

Overall: Pass

Asset ID: 50	Description: Switching Power Adaptor	User: K McCarth	Test Instrument: 40H-0593
--------------	--------------------------------------	-----------------	---------------------------

Comments: Generic

Test Type	Date	Result	Unit	Status
Plug	25/02/2020			Pass
Flex	25/02/2020			Pass
Enclosure	25/02/2020			Pass
Environment	25/02/2020			Pass
Socket	25/02/2020			Pass
Switch	25/02/2020			Pass
Voltage	25/02/2020	230	V	Information
Insulation Voltage	25/02/2020	250	V	Information
Insulation	25/02/2020	> 19.99	MOhm	Pass
Live Voltage	25/02/2020	238.3	V	Information
Load Current	25/02/2020	0.05	A	Information
Touch Current	25/02/2020	0.11	mA	Pass

Overall: Pass

Asset ID: 51	Description: 20 metre 4G Ext Reel	User: K McCarth	Test Instrument: 40H-0593
--------------	-----------------------------------	-----------------	---------------------------

Comments: Jo Jo

Test Type	Date	Result	Unit	Status
Plug	05/03/2020			Pass
Flex	05/03/2020			Pass
Enclosure	05/03/2020			Pass
Socket	05/03/2020			Pass
Voltage	05/03/2020	230	V	Information
Power	05/03/2020	13	A	Information
Rating	05/03/2020	13	Amp	Information
Fuse Rating	05/03/2020	0.46	ohm	Pass
IEC Lead Continuity	05/03/2020	500	V	Information
Insulation Voltage	05/03/2020	> 19.99	MOhm	Pass
Insulation	05/03/2020			Pass
IEC Lead Polarity	05/03/2020			Pass

Overall: Pass

Asset ID: 52	Description: Tyros 5	User: K McCarth	Test Instrument: 40H-0593
--------------	----------------------	-----------------	---------------------------

Comments: Yamaha

Test Type	Date	Result	Unit	Status
Enclosure	05/03/2020			Pass
Environment	05/03/2020			Pass
Socket	05/03/2020			Pass
Switch	05/03/2020			Pass
Voltage	05/03/2020	230	V	Information
Power	05/03/2020	35	W	Information
Rating	05/03/2020	5	Amp	Information
Fuse Rating	05/03/2020	0.12	ohm	Pass
Earth Continuity	05/03/2020	250	V	Information
Insulation Voltage	05/03/2020	> 19.99	MOhm	Pass
Insulation	05/03/2020	244.5	V	Information
Live Voltage	05/03/2020	0.091	A	Information
Load Current	05/03/2020	0.33	mA	Pass
PE Conductor Current	05/03/2020			Pass

# Detailed Test History

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2020 To: 01/04/2020

Overall: Pass

Total Tests: 52